

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL081001</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING: _____	(X3) DATE SURVEY COMPLETED  <b>01/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>COLONIAL MANOR REST HOME</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>160 HEALTH CARE DRIVE RUTHERFORDTON, NC 28139</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments  Report of Biennial Construction Survey by Dennis Harrell on 1-8-2016  Records indicate this facility was first licensed on 1-1-1973, for 34 beds. Based on this information, we are requiring the facility to meet the 1971 Minimum and Desired Standards and Regulations for Homes for the Aged and Infirm, the 1967 NC State Building Code and the applicable portions of the 2005 Rules for Adult Care Homes of Seven or More Beds.	C 000		
C 101	Existing Licensed Fac- No less than '71 Rules  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost;  This Rule is not met as evidenced by: Based on observation the facility failed to meet the provisions of Section 516.1(c) 1. of the 1967 NC State Building Code. Section 516.1(c) 1. required sprinkler systems OR fire detecting	C 101		

Division of Health Service Regulation  
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S

*Brenda J. Feltz - Admin - 2-25-16*

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL081001</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING: _____	(X3) DATE SURVEY COMPLETED  <b>01/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>COLONIAL MANOR REST HOME</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>160 HEALTH CARE DRIVE RUTHERFORDTON, NC 28139</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 101	Continued From page 1  devices be installed in all spaces in accordance with Pamphlets 71, 72, and 74 of the National Fire Protection Association. The Pamphlets stated that fire detecting equipment shall be installed throughout all parts of the protected premises including all rooms, halls, storage areas, etc... Findings include: There was no fire detecting device (a heat or smoke detector connected to the existing fire alarm system) provided in both of the staff bathrooms.	C 101	<i>Heat Sensors were installed</i>	
C 166	Housekeeping-Maintained Free of Hazards  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities.  This Rule is not met as evidenced by: Based on observation, the hose on the hair wash wand in the Beauty Salon was long enough to reach the sink basin and there was no vacuum breaker provided. Hoses on water fixtures that are long enough to reach the flood rim of the fixture present the possibility of siphoning contaminated water into the water system unless a vacuum breaker is installed.	C 166	<i>Vacuum breaker was installed</i>	
C 183	Fire Extinguishers  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0308 FIRE EXTINGUISHERS	C 183		



Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL081001</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING: _____	(X3) DATE SURVEY COMPLETED  <b>01/08/2016</b>
--------------------------------------------------	----------------------------------------------------------------------------	----------------------------------------------------------------------------	-----------------------------------------------------

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

**COLONIAL MANOR REST HOME**

**160 HEALTH CARE DRIVE  
RUTHERFORDTON, NC 28139**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 183	Continued From page 2  (a) At least one five pound or larger (net charge) A-B-C type fire extinguisher is required for each 2,500 square feet of floor area or fraction thereof. (b) One five pound or larger (net charge) A-B-C or CO/2 type is required in the kitchen and, where applicable, in the maintenance shop.  This Rule is not met as evidenced by: Based on a review of documents, the range hood fire suppression system in the kitchen is not being inspected monthly as required. Failure to perform monthly safety inspections could cause the system to fail to work when needed. Findings include: The fire suppression system had not been inspected since October.	C 183	<i>staff has been trained on hood range fire system in kitchen &amp; has begun to sign off on monthly after inspection.</i>	
C 189	Building Equipment Maintained Safe, Operating  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities.  This Rule is not met as evidenced by: 1. Based on observation, many corridor doors are not closing well and/or latching to resist the passage of fire and smoke. Corridor doors that do not close completely and latch present the possibility that a fire that begins in one space can quickly spread to the corridor and the remainder of the facility.	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL081001</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING: _____	(X3) DATE SURVEY COMPLETED  <b>01/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>COLONIAL MANOR REST HOME</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>160 HEALTH CARE DRIVE RUTHERFORDTON, NC 28139</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 3  Findings include; a. The door to bedroom 6 would not latch closed because the latchbolt is missing, b. The door to bedroom 16 was propped open, c. The door to the office was wedged open.  2. Based on observation the required one-hour fire rated walls and/or ceilings were compromised in several locations. Holes and penetrations that are not sealed with materials approved for use in one-hour fire rated construction present the possibility that a fire that begins in one space can quickly spread to other areas of the facility. Findings include: a. Unsealed penetration in ceiling of medication office, b. Holes in ceiling of kitchen, c. Unsealed PVC conduits (2) in laundry.  3. Based on observation, there was a multi outlet adapter in use at the exit/emergency lights in the corridor near rooms 5 and 14. Multi outlet adapters are prohibited. Correct the wiring so the adapter is no longer needed.	C 189  <b>2</b>	<i>A door latch was replaced so that it will close completely B. Carpenter adjusted hinges per your instruction Door stays open. C. Office doors are no longer being wedged open as to meet safety requirements</i>  <b>2.</b> <i>A. All holes that are penetrating B. thru ceiling have now been sealed with fire proof sealant or sheetrock has been replaced &amp; then sealed with fireproof Chalking</i>  <b>3.</b> <i>Multi-Adaptane Unit has been removed &amp; electrician has installed correct exit lights &amp; wiring</i>	
C 191	Unvented & Portable Elec. Heaters Prohibited  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (b) There shall be a heating system sufficient to maintain 75 degrees F (24 degrees C) under winter design conditions. In addition, the following shall apply to heaters and cooking appliances. (2) Unvented fuel burning room heaters and portable electric heaters are prohibited. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e)	C 191		



Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL081001</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING: _____	(X3) DATE SURVEY COMPLETED  <b>01/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>COLONIAL MANOR REST HOME</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>160 HEALTH CARE DRIVE RUTHERFORDTON, NC 28139</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 191	Continued From page 4  which shall not apply to existing facilities.  This Rule is not met as evidenced by: Based on observation the facility failed to adhere to the prohibition of portable electric heaters. Portable electric heaters are a potential fire hazard and as such could effect all occupants of the facility. Findings include: a. There was a portable electric heater in use in the Administration office. b. A portable electric heater was found in the medication office.	C 191	A. Portable heater was removed & an wall mounted gas unit was purchased & installed from the local gas company.  B. Even though heater was not in use it has since been removed. on the day of the walk thru of the facility.	